

CHANAKYA NATIONAL LAW UNIVERSITY

Nyaya Nagar, Mithapur, Patna 1, Ph. No. – 0612-2352300, Website: <https://cnlu.ac.in>

NIQ No.-33/2026-27

Date :-22.08.2026

Emergent Notice Inviting Quotations

Chanakya National Law University invites Sealed quotations in single bid systems from the contractors/reputed firms/companies for Supply, Installation, Testing and commissioning of Feeder pillar and Hot dip Galvanised octagonal pole, Flood light and other related items for University Campus.

The sealed quotations for the following items shall be received in the office of the Registrar, Chanakya National Law University, Mithapur Patna, up to 03:00 PM on 24.08.2026.

The quotations shall be opened on the same day at 03:30 PM in the presence of the quotationers or their authorized representatives.

Feeder Pillar

SI No	Item	Qty	Unit	Unit Rate with GST	Total Amount with GST
1.	Outdoor Feeder Pillar (Panel 72"x80"x14")	1	Sets		
	630 Amp FP Moulded case circuit type of 36 kA (Ics Icu) complete with Microprocessor release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-1 Nos.				
	Control & Meters For Incoming Feeders				
	R/Y/B Phase indication lamps protected through 1set. 2A SP MCB 10kA for each incomer feeder.				
	Indication lamps for On/Off/Trip Status for each incoming breaker along with necessary SD/OF Contacts for breakers.				
	1 set of Digital Ammeter & 1 set of Digital Voltmeter				
	1 set of 630/5A Class-1.0, 15VA Current Transformer for Transformer feeder.				
	Outgoings				
	250 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-4 Nos.				

CHANAKYA NATIONAL LAW UNIVERSITY

Nyaya Nagar, Mithapur, Patna 1, Ph. No. – 0612-2352300, Website: <https://cnlu.ac.in>

NIQ No.-33/2026-27

Date :-22.08.2026

	160 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-4 Nos.				
	100 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-3 Nos.				
	63 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-3 Nos. Busbars				
	TPN Aluminium Busbars of electrolytic grade and minimum of 800Amps capacity with heat shrinkable coloured sleeves and interconnection with DMC/SMC Busbar supports as required. (63x10/30x10/20x10/20x10/25x10)				

SI No	Item	Qty	Unit	Unit Rate with GST	Total Amount With GST
2.	Outdoor Feeder Pillar (Panel 72"x80"x14")	1	Sets		
	630 Amp FP Moulded case circuit type of 36 kA (Ics Icu) complete with Microprocessor release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-1 Nos.				
	Control & Meters For Incoming Feeders				
	R/Y/B Phase indication lamps protected through 1set. 2A SP MCB 10kA for each incomer feeder.				
	Indication lamps for On/Off/Trip Status for each incoming breaker along with necessary SD/OF Contacts for breakers.				
	1 set of Digital Ammeter & 1 set of Digital Voltmeter				
	1 set of 630/5A Class-1.0, 15VA Current Transformer for Transformer feeder.				
	Outgoings				

CHANAKYA NATIONAL LAW UNIVERSITY

Nyaya Nagar, Mithapur, Patna 1, Ph. No. – 0612-2352300, Website: <https://cnlu.ac.in>

NIQ No.-33/2026-27

Date :-22.08.2026

	315 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-4 Nos.				
	200 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-1 Nos.				
	160 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-2 Nos.				
	100 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-2 Nos. Busbars				
	63 Amp FP Moulded case circuit type of 25 kA (Ics=Icu) complete with TM release for OL, S/ C protection, complete with extended Rotary Handle, spreader link etc as reqd. Qty-2 Nos. Busbars				
	TPN Aluminium Busbars of electrolytic grade and minimum of 800Amps capacity with heat shrinkable coloured sleeves and interconnection with DMC/SMC Busbar supports as required. (63x10/30x10/20x10/20x10/25x10/20x10)				
3.	SITC of 12 mtr high hot dip galvanised octagonal poles with 220mm bottom A/F & 90mm top A/F made up of 3mm thk. HR sheet along with base plate of size 320X320X20mm thk. Including ISMC channel bracket for mounting 3 nos flood light having, small door opening for junction box mounting including 16A 'C' series SP MCB, connector, anci suitable size foundation bolts with template as required.(but without pole foundation) (with stairs for maintenance purpose) with T type Bracket.	1	Sets		
4.	Supply and Installation of 400W LED floodlight which should have IP66 Protection , IK 07 Lumen per watt Should be 140 lm/w. fitting should have anti glair optics to prevent glare during game.	1	Sets		
5.	Old Panel repair & Painting work (20 Sq-ft)	1	Sets		
Total Amount					

CHANAKYA NATIONAL LAW UNIVERSITY

Nyaya Nagar, Mithapur, Patna 1, Ph. No. – 0612-2352300, Website: <https://cnlu.ac.in>

NIQ No.-33/2026-27

Date :-22.08.2026

Special Conditions:

1. This quotation is invited only for the purpose of rate determination.
2. The quotationers shall quote their rates both in figures and in words, inclusive of all taxes, GST, and transportation/carriage charges.
3. It is mandatory for the quotationer to submit the Firm Registration Number, GST Registration Number, and PAN along with the quotation.
4. The concerned establishment/firm/supplier shall quote item-wise rates for the items included in the quotation.
5. For further information, please refer to the visit the websites Website: <https://cnlu.ac.in>

REGISTRAR
CNLU, PATNA